

QUIGLEY CREEK OPERATORS

System: Ranchview Estates

Date: 7/16/2025

Water usage:

The total flow through the domestic side of the system for the month of June was 518,852 gallons for an average daily flow rate of 17,295 gallons. Looking back over previous months and years this is right on track with previous readings which indicates no issues within the domestic system. The flow for the irrigation side of the system for June was 6,590,053 gallons for an average daily flow rate of 219,668 gallons. Looking back over previous months and years it is on track with standard usage. However, with the continued issues the high flow rate of irrigation is causing it is encouraged that residents practice water conservation.

Projects:

After a lot of work we were able to finish all of the work needed to upgrade the irrigation system and get both wells back into operation. There have been two new VFD's installed for the irrigation system that will allow us to operate each well independently and have more control of pressures.

Sampling:

Monthly sampling completed without issues.