

# QUIGLEY CREEK OPERATORS

**System: Ranchview Estates**

**Date: 4/12/2025**

## **Water usage:**

The total water usage for the month of March on the domestic side of the system was 426,026 for an average daily flow rate of 13,742 gallons. This is a slight decrease from last month but only by 60 gallons per day so it is extremely close to last month and right on track with previous months which is a good sign of no significant leaks within the domestic system. The total flow for the irrigation side of the system was 14,590 gallons for an average daily flow rate of 470 gallons. This is a large increase from last month by 450 gallons per day but considering the warmer weather it is expected and looking at previous years it is more usage than the last two years but looking at 2022 it is significantly less usage so for now I see no issues within that half of the system.

## **Projects:**

The irrigation system has been flushed using the blow outs on the east end of the system. There is one blow out on the west side of the system but it is unable to be located. The map shows a main valve next to the blow out, the main valve has been located but there are no other valves near the main. I will continue to look for the valve and flush once it is located.

## **Sampling:**

**The monthly sampling has been completed without issue.**